



Certificate / Certificat Zertifikat / 合格証

DC 1308117 C001

exida hereby confirms that the:

FP-700 Combustible Gas Sensor

Detcon

The Woodlands, TX- USA

The manufacturer
may use the mark:



Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 2 (SIL 2 Capable)

Random Capability: Type B Element

SIL 2 @ HFT=0; Route 1_H

**PFD_{AVG} and Architecture Constraints
must be verified for each application**

Safety Function:

The FP-700 is a three-wire 4-20 mA smart device which detects combustible gas hazards. It contains self-diagnostics and is programmed to send its output to a specified failure state upon internal detection of a failure

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



William M. Goff
Evaluating Assessor

John C. Yozallinas
Certifying Assessor



ANSI Accredited Program
PRODUCT CERTIFICATION
#1004

DC 1308117 C001

Systematic Capability: SC 2 (SIL 2 Capable)**Random Capability: Type B Element****SIL 2 @ HFT=0; Route 1_H****PFD_{AVG} and Architecture Constraints
must be verified for each application**FP-700 Combustible
Gas Sensor**Systematic Capability:**

The Product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element.

IEC 61508 Failure Rates in FIT*

Device	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}	SFF
FP-700	0	195	2975	349	90.1%

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: DC 13-08-117 R001 V1 R2

Safety Manual: Safety_Manual_Detcon_FP-700_Gas_Detector_V2



80 N Main St
Sellersville, PA 18960